



Daikin AC (Americas), Inc.
 1645 Wallace Drive, Suite 110
 Carrollton, TX 75006 USA

TEL: 866-4DAIKIN
 FAX: 972-245-1038
 www.daikinac.com

Manufacturer's Certification

Date of issue: January 1, 2013

To Whom It May Concern:

Subject: 2012 & 2013 HVACR Federal Tax Credits for Qualified Energy Property

This certifies that the Daikin Split System Central Air Conditioners and Split System Electric Heat Pumps listed below qualify for the US federal tax credit granted under Title IV – Energy Tax Extenders of The American Taxpayers Relief Act of 2012 herein known as the “Act.”. The “Act” extends the federal tax credits that expired in 2011 from January 1, 2012 until December 31, 2013 for “Qualified Energy Property” listed in Section 25C of the Internal Revenue Code. Because the credits were made retroactive to January 1, 2012, tax credit is available for qualified equipment that was installed any time after December 31, 2011.

The federal tax credit for qualified equipment is 10% of the amount paid but shall not exceed \$300 for the qualified energy property. There is a lifetime limit of \$500 for this credit, meaning if a homeowner has previously claimed the credit (up to \$500), they will be ineligible to claim it on their 2012 and 2013 tax returns. As every taxpayer's situation is different, please consult a tax advisor for the actual credit.

Following Qualified Energy Property must meet or exceed the highest efficiency CEE tier as of January 1, 2009.

HVAC System	CEE Requirements		
	SEER	EER	HSPF
Split System Central Air Conditioner	≥ 16	≥13	N/A
Split System Electric Heat Pump	≥ 15	≥ 12.5	≥ 8.5

Daikin Split System Central Air Conditioners that meet or exceed the highest efficiency CEE tier as of January 1, 2009 are as follows: -

Qualifying Daikin Models			AHRI Certified Ratings		
Daikin System	Outdoor Unit	Indoor Unit	SEER	EER	HSPF
Daikin SkyAir	RZR18PVJU	FBQ18PVJU	17.5	14.1	N/A
	RZR18PVJU	FHQ18PVJU	18.0	14.0	N/A
	RZR18PVJU	FCQ18PAVJU	18.6	13.0	N/A

The values stated above can be verified and Certification Numbers obtained via the CEE/AHRI Verified Directory available at:

<http://www.ahridirectory.org/ceedirectory/pages/ac/cee/defaultSearch.aspx>



Daikin AC (Americas), Inc.
 1645 Wallace Drive, Suite 110
 Carrollton, TX 75006 USA

TEL: 866-4DAIKIN
 FAX: 972-245-1038
 www.daikinac.com

Daikin Split System Heat Pumps that meet or exceed the highest efficiency CEE tier as of January 1, 2009 are as follows: -

Qualifying Daikin Models			AHRI Certified Ratings		
Daikin System	Outdoor Unit	Indoor Unit	SEER	EER	HSPF
Quaternary	RXG09HVJU	FTXG09HVJU	26.1	15.8	11
	RXG12HVJU	FTXG12HVJU	24.2	14.0	10.55
	RXG15HVJU	FTXG15HVJU	21.0	12.9	10.0
Ductless Split System	RXS09JEVJU	FTXS09JEVJU	18.0	12.5	10.0
	RXS12JEVJU	FTXS12JEVJU	18.0	12.5	10.0
	RXS09LVJU	FTXS09LVJU	24.5	15.3	12.5
	RXS12LVJU	FTXS12LVJU	23.0	12.8	12.5
	RXS15LVJU	FTXS15LVJU	20.6	14.4	11.6
	RXS18LVJU	FTXS18LVJU	20.3	12.7	11.0
	RXS24LVJU	FTXS24LVJU	20.0	12.5	10.6
2MXS 2-Port Multi System	2MXS18GVJU	NON-DUCTED INDOOR UNITS	19.5	12.6	9.2
3MXS 3-Port Multi System	3MXS24JVJU	NON-DUCTED INDOOR UNITS	16.6	12.5	9.0
Daikin SkyAir	RZQ18PVJU9	FBQ18PVJU	17.5	14.1	10.6
	RZQ18PVJU9	FHQ18PVJU	18.0	14.0	11.1
	RZQ18PVJU9	FAQ18PVJU	18.6	12.7	8.7
	RZQ18PVJU9	FCQ18PAVJU	18.6	13.0	10.3
	RZQ24PVJU9	FHQ24PVJU	18.0	12.6	10.0
Daikin Inverter Ducted	RZQ18PVJU9	FTQ18PAVJU	18.1	13.9	8.92
	RZQ18PVJU9	FTQ18PBVJU	20.0	14.5	12.0
	RZQ24PVJU9	FTQ24PAVJU	18.0	12.5	8.89
	RZQ24PVJU9	FTQ24PBVJU	19.0	13.5	11.5
	RZQ30PVJU9	FTQ30PBVJU	19.5	13.5	10.0
	RZQ36PVJU9	FTQ36PBVJU	18.0	12.5	9.5

The values stated above can be verified and Certification Numbers obtained via the CEE/AHRI Verified Directory available at:

<http://www.ahridirectory.org/ceedirectory/pages/hp/cee/defaultSearch.aspx>

Under penalties of law, I certify that this statement is correct to the best of my understanding.

Sincerely,

-----  -----

Lee Smith
 Assistant Vice President – Product Marketing
 Daikin AC (Americas), Inc.